

Message

---

**From:** Ewart, Burt [bewart@facil.umass.edu]  
**Sent:** 4/26/2012 1:49:56 PM  
**To:** Hanchett, James (DPH) [/O=COMMONWEALTH OF MASSACHUSETTS/OU=MassMail-01/cn=Recipients/cn=James.Hanchett]  
**Subject:** RE:

Hi, Jim,

I don't think so – You should put in a Service Request to Physical Plant if it's not working.

Burt

**Burt Ewart**

Capital Project Manager  
University of Massachusetts  
Facilities Planning Division  
360 Campus Center Way  
Amherst, MA 01003-9248

[bewart@facil.umass.edu](mailto:bewart@facil.umass.edu)

Direct Extension: 413.577.0128  
Mobile: [REDACTED]  
Office Main: 413.545.1383  
Fax: 413.545.3684

**From:** Hanchett, James (DPH) [mailto:james.hanchett@state.ma.us]  
**Sent:** Thursday, April 26, 2012 9:42 AM  
**To:** Ewart, Burt  
**Subject:**

Hi Burt,

Did you disable the exhaust blower for room N236 when you did renovations for the Vivarium? That is the old exhaust blower number 5. It handles the exhaust for the main lab.

Thanks,

Jim Hanchett  
Amherst Drug Lab  
Room N251 Morrill I  
637 North Pleasant Street  
Amherst, MA 01003  
Phone 413-545-2607  
Fax 413-545-2608  
Cell [REDACTED]